

# CERTIFICATE of Conformity



**Certificate No.:** MK 69241835 0001

**Test Report No.:** 28209533 002

**Certificate Holder:** VENTILATION SYSTEMS PrJSC  
1, Mikhaila Kotzubinskogo str.  
UA-01030 Kiev  
Ukraine

**Manufacturer:** VENTILATION SYSTEMS PrJSC  
36, 40-richchya Zhovtnya str.,  
UA-08150 Boyarka, Kiev region  
Ukraine

**Product:** Air handling unit with heat recovery

**Identification:**

Type designation:	Rated power input:
VUT 200 H mini EC	2x51W
VUT 200 V mini EC	2x51W
VUT 300 H mini EC	2x71W
VUT 300 V mini EC	2x71W
VUT 200 H mini	146W
VUT 200 V mini	146W
VUT 300 H mini	182W
VUT 300 V mini	182W
Trade mark:	VENTS
Rated voltage:	230V, 50Hz
Protection class:	I
Degree of protection:	IP22

**Tested according to:** EN 60335-1:2002+A1+A11+A2+A12+A13+A14  
EN 60335-2-80:2003+A1+A2  
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

**Date of Issue:**

Budapest, 2012.03.22



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu  
IT\_07-D-Pe\_4\_0